



The International Organization for Migration

The Federated States of Micronesia
The Republic of Marshall Islands

Bid Bulletin 1

Date: July 08,2016

Reference No.: TMRP TTK 15/ 680_2016

Project: Supply and Delivery of New House Materials for Typhoon Maysak Reconstruction Project (Chuuk)

Subject: Bid Bulletin 1

Dear Vendors,

This Bid Bulletin 1 is issued to address the clarifications received related to the specifications indicated in the Bill of Quantities (BOQ). Please refer to those highlighted in **Red**.

Item 28, 8d Nails x 2-1/2" long - **40 lbs.**

Item 29, 8d Nails x 1-1/2" long – **the length of 1-1/2" is correct (see below reference)**

Simpson Strong-Tie | Model # N8DHDG-R |
Strong-Drive 8d x 1-1/2 in.

RECOMMENDED ITEMS | PRODUCT OVERVIEW | **SPECIFICATIONS** | QUESTIONS & ANSWERS | CUSTOMER REVIEWS

SPECIFICATIONS

■ DIMENSIONS

Assembled Depth (in.)	2.375 in	Fastener head width (in.)	0.297
Assembled Height (in.)	4.375 in	Fastener length (in.)	1.5
Assembled Width (in.)	5.25 in	Nail Length (in.)	1 1/2

■ DETAILS

Fastener Callout Size	8d x 1 1/2 in.	Nail Type	Wood Joiner Nail
Fastener Type	Non-Collated Nail	Package Quantity	1
Fastener/Connector Material	Steel	Product Weight (lb.)	1 lb
Finish Family	Silver	Returnable	90-Day
Indoor/Outdoor	Indoor/Outdoor		

Note: Doesn't have to be strong-tie brand (any brand will do)

Item 34, Electrical tape ¾" x 60'/rl. – 2 rolls

Item 16, # 3 Deformed Bar x 24 –inch long, grade 40 epoxy coated

Note: #3 are rebar sizes meaning 3/8" diameter

Item 17, #4 Deformed Bar x 12 –inch long, grade 40 epoxy coated

Note 1: #4 are rebar sizes meaning ½"(4/8")diameter.

Note 2: Length is now 12 inch from 18 inch.

This is only applicable to Item 17 only.

End of Bid Bulletin 1.