



Date: September 19th,2016

Reference No.: TMRP YAP16/100_2016

Project: Supply and Delivery of Materials for Public Infrastructure Repair Works for Typhoon Maysak Reconstruction Project (Yap, FSM)

Subject: Bid Bulletin 2- Clarification on RfQ items

Dear Vendors,

This Bid Bulletin 2 is issued to inform all the Bidders on the questions raised regarding the following;

- Question 1; Simpson tie description is too generic.

Strong Simpsons tie Z-MAX Galvanized 18-Gauge Hurricane Tie/ or two fold Ga 25/24 g.i plane wrap around Purlins to TC or Rafter	2,315	pcs
Strong Simpsons Z-MAX Galvanized 18-Gauge Hurricane Tie/ or two fold Ga 25/24 g.i plane wrap around member to TC and BC	810	pcs

Answer: Strong Simpsons tie Z-MAX Galvanized 18-Gauge Hurricane Tie or equivalent.

- Question 2; Jalousie windows acceptable size and color.

Answer: The sizing that is acceptable is as follows (incl or excluding two operators per window);

Width 2" even increments from 12" to 40" (tip to tip which includes a ½" side flange)

Height with a tip to tip measurement that includes a ½" top & bottom flange.

Preferred color is white.

Bid Submission date is **September 20th, 2016**.

End of Bid Bulletin 2.

Thank you and Regards,

Procurement Micronesia