## Project: Supply and delivery of construction materials for 9 Repairs of Public Infrastructure and Utilities, Northwest, Chuuk, Federated States of Micronesia

Bid Bulletin No. 3

Date: June 5<sup>th</sup>, 2023

Responses and comments to general and technical requirements with regard to the ITB on Supply and delivery of construction materials for 9 Repairs of Public Infrastructure and Utilities, Northwest, Chuuk, Federated States of Micronesia

## 1. There are a few items in question.

56	Aggregate Base Course, Mobile Mix, 0.33 cu.yd. per bag, conform with ASTM C 136 & C 117, Packaged as per Supplier's specifications	
61	Aluminum double swing door, 5'9 1/2"X6'10" size, with glass shutters, and other fittings/locks	
Aluminum sliding windows with insect screen, 3'd 1/2"X3'4 1/2" size, with glass shutters and other fittings/locks		
Door Framing Aluminum with groove for 1/4" Glass, 1/8"x2"x4"x 12' long, Powder Coated W		
114	Double Furring, Galvanized 3/4" x 2" x 16.5', (0.6mm) thickness	
Embankment Aggregate Materials conform with ASTM D422 & D854, 0.33 cu. yd. per bag, Packing as per Supplier's specifications		
136	Interlink Fence Wire 3.5mmx2"x2" (opening)x7' (50ft), HDG	
275	Sliding Window Aluminum Frame 1/8"x1"x2"x12' (groove) for 1/4" thick Glass, Powder Coated White	
281	Steel Self-Drilling Screw, Sealing Hex Washer Head With EPDM Washer #3 Drill Point, 1/4"-14 Thread Size, 5" Length (Pack of 10)	
305	W-Clip	

The above items are in questions as we need more information to be able to quote them. Please provide more information for the above items.

98	C-purlins 2"x4"x20' Ga. 14, HDG	
99	C-Purlins, HDG, 1 1/2"x2"x20'x5/64"	
100	C-Purlins, HDG, 1 1/2"x3"x20'x5/64"	

101	C-Purlins, HDG, 2"x2"x20'x5/64"
102	C-Purlins, HDG, 2"x6"x20'x5/64"

Do you have any drawings for the above items?


## IOM Response: Here please additional information and drawing:

98 C-p	ourlins 2"x4"x20' Ga. 14, HDG	sample 2"x4"x20' Ga. 14, HDG
99 C-P	rurlins, HDG, 11/2"x2"x20'x5/64"	a=2 <sup>n</sup>
100 C-P	rurlins, HDG, 1 1/2"x3"x20'x5/64"	b
101 C-P	rurlins, HDG, 2"x2"x20'x5/64"	b=4"
102 C-P	rurlins, HDG, 2"x6"x20'x5/64"	c=20' (length)
'	'	Ga. = Gauge (Thickness) HDG = Hot dipped galvanize  Item Figure
305	W-Clip	
114	Double Furring, Galvanized 3/4" x 2" x 16.5', (0.6mm) thickness	
136	Interlink Fence Wire 3.5mmx2"x2" (opening)x7' (50ft), HDG	
		opening = 2" x 2" (diamond)
		wire thickness = 3.5mm roll hieght = 7'-0"
		roll longth = FOLO!!
		roll length = 50'-0"

Steel Self-Drilling Screw, Sealing Hex Washer
Head With EPDM Washer #3 Drill Point, 1/4"-14
Thread Size, 5" Length (Pack of 10)



		Change to 2 1/2" length
		NOTE:  1. SHATTERED/BROKEN GLASS FOR DOORS & WINDOWS SHALL BE REPLACED WITH NEW UNITS.  2. ACCESSORIES & FITTINGS ARE INCLUDED ON THE SET.
		5'-9 1/2*
		2'-10 3/4" 2'-10 3/4"
61	Aluminum double swing door, 5'9 1/2"X6'10" size, with glass shutters, and other fittings/locks	GLASS
		// // // //
		D1  NEW ALUMINUM DOUBLE SWING DOOR  (1-UNIT)



105	Door Framing Aluminum with groove for 1/4" thick Glass, 1/8"x2"x4"x 12' long, Powder Coated White	TO FIT 4" THK.  7/8" 1/4" 7/8"  4" 3 1/2"  DOOR ALUMINUM FRAME PROPILE ITEM No. 105
275	Sliding Window Aluminum Frame 1/8"x1"x2"x12' (groove) for 1/4" thick Glass, Powder Coated White	TO FIT 1" THK.  GLASS  1/4"  3/8"  1/2"  1/2"  1/2"  DOOR ALUMINUM FRAME PROFILE ITEM No. 275
56	Aggregate Base Course, Mobile Mix, 0.33 cu.yd. per bag, conform with ASTM C 136 & C 117 , Packaged as per Supplier's specifications	https://www.homedepot.com/p/Mobile-Mix-0-33-of-cu-yd-AB-Base- 000001/203182215
115	Embankment Aggregate Materials conform with ASTM D422 & D854, 0.33 cu. yd. per bag, Packing as per Supplier's specifications	https://www.lowes.com/pd/QUIKRETE-0-33-cu-yd/50261851
		Note: compatable product equivalent shown on the link