



International Organization for Migration (IOM)
The UN Migration Agency

Date. 02/05/2023

Bid Bulletin No 3

Construction works at Pournara First Reception Center in Cyprus

ITB Ref.: ITB 2023.CYP.03.MC

Question 1:

What procedure/documentation is needed in order contractors to work in the camp (with regards to entrance to the camp and security)?

Answer 1:

The awarded bidder shall provide a list of personnel/manpower to IOM. IOM in coordination with Cypriot authorities will provide access to the camp. The location will be a construction area accessible only to staff related with the works.

Question 2:

Is there is a section drawing or detail with the thicknesses of bases underneath road paving in the surrounding area?

Answer 2:

Please refer to the Technical Description document of the Tender, paragraph 3.4. More specifically, 1 layer of 10cm average depth, 1 layer of bituminous adhesive coating, 1 layer of bituminous layer 5cm thick. All the above works will take place after the removal of loose surface material and backfilling with quarry material (20cm depth) in order to create a "healthy" surface, as shown in article 2 and article 5 of the BoQs (under section Surrounding area).

Question 3:

What type of trees are needed to be planted?

Answer 3:

We propose to use the same type with the existing ones in the camp, pine trees (*Pinus halepensis*). An alternative, and in case they are not of the same type, could be *Morus platanifolia* 'fruitless'. Either type should be around 2m high.

IOM Greece
Dodekanisou 6, 17456, Alimos
Athens, Greece